



CERTIFICATE OF SUITABILITY

THIS is to certify that articles of the same type as the article specified below and variations so specified are accepted by the DEPARTMENT OF ENERGY as suitable for connection to public electricity supply in NEW SOUTH WALES in accordance with the provisions of AS 3000 subject to the conditions stated.

Article:

Component, 1 & 3 phase duct heating unit comprising sheathed-type finned elements mounted on a sheet metal enclosure housing the element connections and overtemperature protective devices.
240/415V 50Hz 0.5-50kW
Class I

Identification: KEM Series

Examined for compliance with: AS 3102-1983

Issued to: KEM Duct Heaters

Nominated Marking: CS6991N

Conditions:

1. This certificate will be withdrawn automatically if an article of this type is declared pursuant to Section 21 of the Electricity Act, 1945.
2. This certificate is issued subject to the article and accepted variations thereof being maintained at the standard of the article examined at the time of acceptance.
3. *To be installed within an electric duct heater in accordance with AS 3102.*

Approved: 10 March 1997

R S W Neil
DIRECTOR-GENERAL

Mr Damien Robertson
Grimwood Heating Pty Ltd
PO Box 4
VILLAWOOD NSW 2163

File Ref: Ref: CS6991/3
Contact: Admin Clerk
Telephone: 02 9895 0722
Fax: 02 9895 0735

Dear Sir/Madam

RENEWAL OF CERTIFICATE OF SUITABILITY:6991

Duct Heater

Please find enclosed an addendum to the certificate as sought in your application.

Approved articles may now be marked with either

(a) the mark (or marks) as shown on the Certificate; or

(b) the Regulatory Compliance Mark (RCM) provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled.

THE APPROVAL NOW EXPIRES ON 23 January 2014 unless it is renewed, extended, suspended or cancelled.

Any sample/s held by the Office should be collected within fifteen (15) days of this letter or the sample/s will be destroyed.

Yours faithfully



for Commissioner for Fair Trading
02 April 2009

Ref: CS6991/3

RENEWAL OF CERTIFICATE OF SUITABILITY 6991

PARTICULARS OF RENEWAL

The approval of the original KEM Series has been renewed.

Date of Renewal: 23 January 2009

The Approval expires on 23 January 2014 unless it is renewed, extended, suspended or cancelled.

A handwritten signature in black ink, appearing to be the initials 'AK' followed by a flourish.

for Commissioner for Fair Trading